

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-0026:288 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Models ISC-350DIDC, ISC-350DPDC, ISC-350DIAC, ISC-350DPAC duct detector housings/bases. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as duct detector bases for use with separately listed compatible detector heads and control units when installed in HVAC systems with velocity between 500 and 3000 ft./min. All models utilizes Hochiki's Model SIH-24FAP (CSFM Listing No. 7271-0410:135) or Model SLK-24F (CSFM Listing No. 7272-0410:107) or Apollo's Model 55000-250 (CSFM Listing No. 7271-1394:101) or 55000-350 (CSFM Listings No. 7272-1394:100) detectors.

NOTE: Formerly 3240-0062:163, 3240-1493:163

XLF: 3240-1004:100

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**